

Johnson Controls



Charlottesville Airport Controls Upgrade




Creating a better climate for business.

- ☐ Environmental Control System
- ☐ Facility Management System
- ☐ Air and Water System Balancing
- ☐ Fire Management System
- ☐ Security System
- ☐ Lighting Services
- ☐ Instrumentation System Installation
- ☐ Building Operations Management
- ☐ Energy Conservation Control
- ☐ Training Programs
- ☐ Performance Contracting
- ☐ Planned Service Agreements

Air Conditioning
Heating
Diagnostic Services
Coil Cleaning
Refrigeration
Automatic Temperature Controls
Facility Management Systems
Fire Management
Security Management
Building Operations and Management
Water Treatment
Electrical Equipment
Emergency Generator / Lighting Equipment
Industrial Controls / Recording / Indication Equipment

LEGEND




PROJECT TITLE	
Charlottesville Airport Controls Upgrade	
ARCHITECT	ENGINEER
Phone:	Phone:
MECHANICAL CONTRACTOR	ELECTRICAL CONTRACTOR
Phone:	Phone:
REFERENCE DRAWING	NO.
REVISION-LOCATION	ECN
DATE	BY
Branch Information	
2315 Commerce Center Dr Suite D Rockville VA 23146	
Phone: 1-866-272-6406	
SALES ENGINEER	PROJECT MANAGER
APPLICATION ENGINEER	DATE
CONTRACT NUMBER	
1-2744395808	

Network Riser

BILL OF MATERIALS

Designation	Qty	Part Number	Description
CA-ADS01	1	ADSTK-0	Application Data Server Turnkey
CA-NAE01	1	MS-NAE5510-1	Network Automation Engine


Maintenance
Office



OPTIONAL
ROUTER

OPTIONAL
FIREWALL

OPTIONAL
INTERNET
CONNECTION



ETHERNET


MS/TP

MS/TP


MS/TP

MS/TP


MS/TP




CA-NAE01
IP-10.10.10.10
1st Floor
IT Closet




CHILLER
1st Floor
Mechroom



BOILER
1st Floor
Mechroom



AHU-1
1st Floor
Mechroom



AHU-5
1st Floor
Mechroom



TERMINAL UNIT
Typical of 31
SEE ROOM SCHEDULE
FOR ADDRESS AND
LOCATION
INFORMATION



AHU-2
2nd Floor
Mechroom




AHU-3
2nd Floor
Mechroom



TERMINAL UNIT
Typical of 31
SEE ROOM SCHEDULE
FOR ADDRESS AND
LOCATION
INFORMATION

SHIELD GROUNDING



If a shield is used, it should be earth grounded at one and only one point for the entire bus segment. (Preferably in the NAE panel.) The shield screws on the controllers are simply a convenient way to continue the daisy chain of the bus. They are not attached to earth ground.

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND.

COPYRIGHT JOHNSON CONTROLS, INC. 2007

Drawing Title

NET Network Riser

Project Title

Charlottesville Airport
Controls Upgrade

Johnson
Controls

2315 Commerce
Center Dr
Suite D
Rockville VA 23146


1-2744395808

NT-1

Boiler Plant

BILL OF MATERIALS

<u>Designation</u>	<u>Qty</u>	<u>Part Number</u>	<u>Description</u>
HWS-T,HWR-T	2	TE-631AM-1	1000 OHM NICKEL SENSOR WELL INSERTION
BOILER	1	MS-FEC2621-0	17 PT FIELD EQUIPMENT CONTROLLER
	1	MS-IOM4711-0	17 PT IO MODULE



HOT WATER PUMP CONTROL: THE HOT WATER PUMP WITH THE LOWEST RUNTIME WILL AUTOMATICALLY START WHEN THE OUTSIDE AIR TEMPERATURE FALLS BELOW THE SYSTEM ENABLE SETPOINT. WHEN THE OUTSIDE AIR TEMPERATURE RISES ABOVE THIS SETPOINT, THE HOT WATER PUMPS WILL TURN OFF. WHEN ENABLED, THE LEAD PUMP WILL START AND RUN CONTINUOUSLY. IF FOR ANY REASON ITS STATUS DOES NOT MATCH ITS COMMANDED VALUE AN ALARM WILL BE GENERATED. THE LAG PUMP WILL START IF THE LEAD PUMP IS IN ALARM. WHENEVER THE SYSTEM IS COMMANDED OFF, THE LEAD HOT WATER PUMP WILL RUN FOR A PERIOD OF TIME TO DISPATE THE HEAT IN THE SYSTEM.

BOILER CONTROL: THE BOILER CONTROL SEQUENCE WILL BEGIN WHEN ONE OF THE HOT WATER PUMPS HAS A STATUS OF ON. WHEN A BOILER ENABLE COMMAND IS SENT, THE COMBUSTION DAMPERS SHALL OPEN AND THE BOILER WILL FIRE. THE BOILER WILL CYCLE TO MAINTAIN THE HOT WATER RETURN TEMPERATURE AT A SETPOINT AND IS RESET INVERSLY TO THE OUTSIDE AIR TEMPERATURE. THE BOILERS SAFETIES CIRCUIT WILL BE MONITORED AND THE SYSTEM WILL REPORT A GENERAL ALARM CONDITION IF A SAFETY IS TRIPPED. A MANUAL RESET OF THE BOILER SAFETY WILL BE REQUIRED BEFORE THE BOILER CAN BE RESTARTED.

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND.

COPYRIGHT JOHNSON CONTROLS, INC. 2007

Drawing Title

HWS Flow Layout

Project Title	
---------------	--

Charlottesville Airport Controls Upgrade

REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
Sales Engineer	Project Manager	Application Engineer	DRAWN		APPROVED		
			BY	DATE	BY	DATE	
			Branch Information		CONTRACT NUMBER		
			2315 Commerce Center Dr Suite D Rockville VA 23146		1-2744395808		
					DRAWING NUMBER BLR-1		


Electrician/Fitter		Point Information			Controller Information						Panel Information					Intermediate Device			
	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device
Tag																			
					FEC 26xx														
					FEC 26xx	MS/TP	1	6						0					
	UI IN-1	AHU-3	DA-T	Discharge Air Temperature	FEC 26xx	MS/TP	1	6	UI IN-1					0		-6-UI IN-1			
	UI IN-2	AHU-3	DA1-P	Discharge Air Static Pressure	FEC 26xx	MS/TP	1	6	UI IN-2					0		-6-UI IN-2			
	UI IN-3	AHU-3	MA-T	Mixed Air Temperature	FEC 26xx	MS/TP	1	6	UI IN-3					0		-6-UI IN-3			
	UI IN-4	AHU-3	RA-T	Return Air Temperature	FEC 26xx	MS/TP	1	6	UI IN-4					0		-6-UI IN-4			
	UI IN-5	AHU-3	RA-H	Return Air Humidity	FEC 26xx	MS/TP	1	6	UI IN-5					0		-6-UI IN-5			
	UI IN-6	AHU-3			FEC 26xx	MS/TP	1	6	UI IN-6					0		-6-UI IN-6			
	BI IN-7	AHU-3	LT-A	Low Temperature Alarm	FEC 26xx	MS/TP	1	6	BI IN-7					0		-6-BI IN-7			
	BI IN-8	AHU-3	SF-S	Supply Fan Status	FEC 26xx	MS/TP	1	6	BI IN-8					0		-6-BI IN-8			
	BO OUT-1	AHU-3	EF2-C	Exhaust Fan 2 Command	FEC 26xx	MS/TP	1	6	BO OUT-1					0		-6-BO OUT-1			
	BO OUT-2	AHU-3	SF-C	Supply Fan Command	FEC 26xx	MS/TP	1	6	BO OUT-2					0		-6-BO OUT-2			
	BO OUT-3	AHU-3			FEC 26xx	MS/TP	1	6	BO OUT-3					0		-6-BO OUT-3			
	CO OUT-4	AHU-3	SF-O	Supply Fan Output	FEC 26xx	MS/TP	1	6	CO OUT-4					0		-6-CO OUT-4			
	CO OUT-5	AHU-3			FEC 26xx	MS/TP	1	6	CO OUT-5					0		-6-CO OUT-5			
	CO OUT-6	AHU-3			FEC 26xx	MS/TP	1	6	CO OUT-6					0		-6-CO OUT-6			
	CO OUT-7	AHU-3			FEC 26xx	MS/TP	1	6	CO OUT-7					0		-6-CO OUT-7			
	AO OUT-8	AHU-3	CLG-O	Cooling Output	FEC 26xx	MS/TP	1	6	AO OUT-8					0		-6-AO OUT-8			
	AO OUT-9	AHU-3	MAD-O	Mixed Air Damper Output	FEC 26xx	MS/TP	1	6	AO OUT-9					0		-6-AO OUT-9			

Electrician/Fitter		Point Information				Controller Information					Panel Information							Intermediate Device	
Tag	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device
					FEC 26xx														
					FEC 26xx	MS/TP	1	9						0					
	UI IN-1	BOILER	OA-H	Outdoor Air Humidity	FEC 26xx	MS/TP	1	9	UI IN-1					0		-9-UI IN-1			
	UI IN-2	BOILER	PHWR-T	Primary HW Return Temp	FEC 26xx	MS/TP	1	9	UI IN-2					0		-9-UI IN-2			
	UI IN-3	BOILER	PHWS-T	Primary HW Supply Temp	FEC 26xx	MS/TP	1	9	UI IN-3					0		-9-UI IN-3			
	UI IN-4	BOILER	PHWP1-S	Primary HW Pump 1 Status	FEC 26xx	MS/TP	1	9	UI IN-4					0		-9-UI IN-4			
	UI IN-5	BOILER	PHWP2-S	Primary HW Pump 2 Status	FEC 26xx	MS/TP	1	9	UI IN-5					0		-9-UI IN-5			
	UI IN-6	BOILER			FEC 26xx	MS/TP	1	9	UI IN-6					0		-9-UI IN-6			
	BI IN-7	BOILER	BLR1-A	Boiler 1 Alarm	FEC 26xx	MS/TP	1	9	BI IN-7					0		-9-BI IN-7			
	BI IN-8	BOILER	BLR1-S	Boiler 1 Status	FEC 26xx	MS/TP	1	9	BI IN-8					0		-9-BI IN-8			
	BO OUT-1	BOILER	BLR1-C	Boiler 1 Command	FEC 26xx	MS/TP	1	9	BO OUT-1					0		-9-BO OUT-1			
	BO OUT-2	BOILER	PHWP1-C	Primary HW Pump 1 Command	FEC 26xx	MS/TP	1	9	BO OUT-2					0		-9-BO OUT-2			
	BO OUT-3	BOILER	PHWP2-C	Primary HW Pump 2 Command	FEC 26xx	MS/TP	1	9	BO OUT-3					0		-9-BO OUT-3			
	CO OUT-4	BOILER			FEC 26xx	MS/TP	1	9	CO OUT-4					0		-9-CO OUT-4			
	CO OUT-5	BOILER			FEC 26xx	MS/TP	1	9	CO OUT-5					0		-9-CO OUT-5			
	CO OUT-6	BOILER			FEC 26xx	MS/TP	1	9	CO OUT-6					0		-9-CO OUT-6			
	CO OUT-7	BOILER			FEC 26xx	MS/TP	1	9	CO OUT-7					0		-9-CO OUT-7			
	AO OUT-8	BOILER			FEC 26xx	MS/TP	1	9	AO OUT-8					0		-9-AO OUT-8			
	AO OUT-9	BOILER			FEC 26xx	MS/TP	1	9	AO OUT-9					0		-9-AO OUT-9			

Chiller Plant

BILL OF MATERIALS

Designation	Qty	Part Number	Description
CHWS-T,CHWR-T	4	TE-631AM-1	1000 OHM NICKEL SENSOR WELL INSERTION
CWS-T,CWR-T			
CHILLER	1	MS-FEC2621-0	17 PT FIELD EQUIPMENT CONTROLLER
	1	MS-IOM4711-0	17 PT IO MODULE



CHILLER CONTROL: THE CHILLER WILL BE ENABLED WHEN THE OUTSIDE AIR TEMPERATURE RISES ABOVE THE SYSTEM ENABLE SETPOINT. WHEN THE OUTSIDE AIR TEMPERATURE FALLS BELOW THIS SETPOINT, THE CHILLER WILL TURN OFF. WHEN ENABLED, THE CHILLER WILL, AND THE PUMP (S) WILL BE COMMANDED ON, SEE BELOW. ONCE THE CHILLER RECEIVES FLOW STATUS IT WILL, VIA ITS INTERNAL CONTROLS, MAINTAIN THE CHILLED WATER SUPPLY TEMPERATURE AT SETPOINT. IF ANY CHILLERS CHILLED WATER ISOLATION VALVE STATUS DOES NOT MATCH ITS COMMANDED VALUE AFTER A PERIOD OF TIME FOLLOWING BEING ENABLED, AN ALARM WILL BE GENERATED. IF THE CHILLER IS LEAD AT THE TIME OF THE ALARM THE LAG CHILLER WILL BE ENABLED.

CHILLED WATER PUMP CONTROL: THE CHILLED WATER PUMP WITH THE LOWEST RUNTIME WILL AUTOMATICALLY START WHEN EITHER CHILLED WATER ISOLATION VALVE HAS A STATUS OF OPEN. IF BOTH ISOLATION VALVES ARE OPEN THEN BOTH PUMPS WILL RUN. WHEN ENABLED, THE PUMPS WILL START AND RUN CONTINUOUSLY. IF FOR ANY REASON ITS STATUS DOES NOT MATCH ITS COMMANDED VALUE AN ALARM WILL BE GENERATED. THE LAG PUMP WILL START IF THE LEAD PUMP IS IN ALARM.

CONDENSER WATER PUMP CONTROL: THE CONDENSER WATER PUMP WITH THE LOWEST RUNTIME WILL AUTOMATICALLY START WHEN EITHER CONDENSER WATER ISOLATION VALVE HAS A STATUS OF OPEN. IF BOTH ISOLATION VALVES ARE OPEN THEN BOTH PUMPS WILL RUN. WHEN ENABLED, THE PUMPS WILL START AND RUN CONTINUOUSLY. IF FOR ANY REASON ITS STATUS DOES NOT MATCH ITS COMMANDED VALUE AN ALARM WILL BE GENERATED. THE LAG PUMP WILL START IF THE LEAD PUMP IS IN ALARM.


CONDENSER WATER CONTROL: WHEN EITHER CONDENSER WATER PUMP STATUS IS ON THE COOLING TOWER BYPASS, AND COOLING TOWER FANS WILL MODULATE OR CYCLE TO MAINTAIN THE CONDENSER WATER SUPPLY TO THE CHILLERS AT SETPOINT.

COOLING TOWER CONTROL: THE COOLING TOWER FAN WITH THE LOWEST RUNTIME WILL AUTOMATICALLY START WHEN THE COOLING BYPASS VALVE IS INDEXED FOR FLOW OVER THE TOWER AND MORE COOLING IS REQUIRED. THE COOLING TOWER FAN WILL CHANGE SPEEDS TO MAINTAIN CONDENSER WATER SETPOINT. IF FURTHER COOLING IS REQUIRED THE NEXT CELL WILL BE ENABLED AND OPERATE SIMILARLY WHILE, THIS CELL PROVIDES MAXIMUM COOLING. IF FOR ANY REASON ITS FAN STATUS DOES NOT MATCH ITS COMMANDED VALUE AN ALARM WILL BE GENERATED.

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND. COPYRIGHT JOHNSON CONTROLS, INC. 2007	Drawing Title											
	Chiller Flow Layout											
Project Title		Charlottesville Airport Controls Upgrade				Branch Information		2315 Commerce Center Dr Suite D Rockville VA 23146		CONTRACT NUMBER 1-2744395808		
										DRAWING NUMBER CH-1		

Electrician/Fitter		Point Information			Controller Information							Panel Information						Intermediate Device		
	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device	
Tag																				
					FEC 26xx															
					FEC 26xx	MS/TP	1	8						0						
	UI IN-1	CHILLER	CWS-T	Condenser Water Supply Temp	FEC 26xx	MS/TP	1	8	UI IN-1					0		-8-UI IN-1				
	UI IN-2	CHILLER	PCHWR-T	Primary CHW Return Temp	FEC 26xx	MS/TP	1	8	UI IN-2					0		-8-UI IN-2				
	UI IN-3	CHILLER	PCHWS-T	Primary CHW Supply Temp	FEC 26xx	MS/TP	1	8	UI IN-3					0		-8-UI IN-3				
	UI IN-4	CHILLER	CWP2-S	Condenser Water Pump 2 Status	FEC 26xx	MS/TP	1	8	UI IN-4					0		-8-UI IN-4				
	UI IN-5	CHILLER	PCHWP1-S	Primary CHW Pump 1 Status	FEC 26xx	MS/TP	1	8	UI IN-5					0		-8-UI IN-5				
	UI IN-6	CHILLER	PCHWP2-S	Primary CHW Pump 2 Status	FEC 26xx	MS/TP	1	8	UI IN-6					0		-8-UI IN-6				
	BI IN-7	CHILLER	CH1-S	Chiller 1 Status	FEC 26xx	MS/TP	1	8	BI IN-7					0		-8-BI IN-7				
	BI IN-8	CHILLER	CWP1-S	Condenser Water Pump 1 Status	FEC 26xx	MS/TP	1	8	BI IN-8					0		-8-BI IN-8				
	BO OUT-1	CHILLER	CH1-EN	Chiller 1 Enable	FEC 26xx	MS/TP	1	8	BO OUT-1					0		-8-BO OUT-1				
	BO OUT-2	CHILLER	CWP1-C	Condenser Water Pump 1 Control	FEC 26xx	MS/TP	1	8	BO OUT-2					0		-8-BO OUT-2				
	BO OUT-3	CHILLER	CWP2-C	Condenser Water Pump 2 Control	FEC 26xx	MS/TP	1	8	BO OUT-3					0		-8-BO OUT-3				
	CO OUT-4	CHILLER	PCHWP1-C	Primary CHW Pump 1 Command	FEC 26xx	MS/TP	1	8	CO OUT-4					0		-8-CO OUT-4				
	CO OUT-5	CHILLER	PCHWP2-C	Primary CHW Pump 2 Command	FEC 26xx	MS/TP	1	8	CO OUT-5					0		-8-CO OUT-5				
	CO OUT-6	CHILLER	CT1L-C	Tower 1 LO Command	FEC 26xx	MS/TP	1	8	CO OUT-6					0		-8-CO OUT-6				
	CO OUT-7	CHILLER	CT1H-C	Tower 1 HI Command	FEC 26xx	MS/TP	1	8	CO OUT-7					0		-8-CO OUT-7				
	AO OUT-8	CHILLER	CTV-O	Tower Valve Output	FEC 26xx	MS/TP	1	8	AO OUT-8					0		-8-AO OUT-8				
	AO OUT-9	CHILLER			FEC 26xx	MS/TP	1	8	AO OUT-9					0		-8-AO OUT-9				
					IOM 4710															
					IOM 4710	SA Bus	1	4						0						
	UI IN-1	CHILLER			IOM 4710	SA Bus	1	4	UI IN-1					0		8--4-UI IN-1				
	UI IN-2	CHILLER			IOM 4710	SA Bus	1	4	UI IN-2					0		8--4-UI IN-2				
	UI IN-3	CHILLER			IOM 4710	SA Bus	1	4	UI IN-3					0		8--4-UI IN-3				
	UI IN-4	CHILLER			IOM 4710	SA Bus	1	4	UI IN-4					0		8--4-UI IN-4				
	UI IN-5	CHILLER			IOM 4710	SA Bus	1	4	UI IN-5					0		8--4-UI IN-5				
	UI IN-6	CHILLER			IOM 4710	SA Bus	1	4	UI IN-6					0		8--4-UI IN-6				
	BI IN-7	CHILLER	CT1-S	Tower 1 Status	IOM 4710	SA Bus	1	4	BI IN-7					0		8--4-BI IN-7				
	BI IN-8	CHILLER			IOM 4710	SA Bus	1	4	BI IN-8					0		8--4-BI IN-8				
	BO OUT-1	CHILLER			IOM 4710	SA Bus	1	4	BO OUT-1					0		8--4-BO OUT-1				
	BO OUT-2	CHILLER			IOM 4710	SA Bus	1	4	BO OUT-2					0		8--4-BO OUT-2				
	BO OUT-3	CHILLER			IOM 4710	SA Bus	1	4	BO OUT-3					0		8--4-BO OUT-3				
	CO OUT-4	CHILLER			IOM 4710	SA Bus	1	4	CO OUT-4					0		8--4-CO OUT-4				
	CO OUT-5	CHILLER			IOM 4710	SA Bus	1	4	CO OUT-5					0		8--4-CO OUT-5				
	CO OUT-6	CHILLER			IOM 4710	SA Bus	1	4	CO OUT-6					0		8--4-CO OUT-6				
	CO OUT-7	CHILLER			IOM 4710	SA Bus	1	4	CO OUT-7					0		8--4-CO OUT-7				
	AO OUT-8	CHILLER			IOM 4710	SA Bus	1	4	AO OUT-8					0		8--4-AO OUT-8				
	AO OUT-9	CHILLER			IOM 4710	SA Bus	1	4	AO OUT-9					0		8--4-AO OUT-9				

AHU-1



BILL OF MATERIALS

Designation	Qty	Part Number	Description
RA-T,DA-T	2	TE-6311M-1	1000 OHM NICKEL SENSOR
MA-T	1	TE-6316M-1	NICKEL DUCT AVERAGE SENSOR
AHU-1	1	MS-FEC2621-0	17 PT FIELD EQUIPMENT CONTROLLER

SUPPLY FAN START/STOP: THE SUPPLY FAN WILL BE STARTED ACCORDING TO THE SCHEDULE. IF THE SUPPLY FAN STATUS DOES NOT MATCH THE COMMANDED VALUE, AN ALARM WILL BE GENERATED. WHEN THE SUPPLY FAN STATUS INDICATES THE FAN STARTED, THE CONTROL SEQUENCE WILL BE ENABLED.

STATIC PRESSURE CONTROL: THE SUPPLY FAN WILL MODULATE TO MAINTAIN THE DISCHARGE STATIC PRESSURE AT SETPOINT 1.0 INWC (ADJUSTABLE).

DISCHARGE AIR CONTROL: THE MIXED AIR DAMPERS, AND THE COOLING VALVE WILL MODULATE IN SEQUENCE TO MAINTAIN THE DISCHARGE AIR TEMPERATURE AT SETPOINT 55 DEGF (ADJUSTABLE).

MIXED AIR LOW LIMIT OVERRIDE: THE MIXED AIR TEMPERATURE WILL OVERRIDE THE MINIMUM POSITION AND CLOSE THE OUTSIDE AIR DAMPER IF A TEMPERATURE IS SENSED BELOW THE SETPOINT 50 DEGF (ADJUSTABLE).

ECONOMIZER DRY BULB SWITCHOVER: WHEN THE SHARED OUTSIDE AIR TEMPERATURE IS BELOW THE SWITCHOVER SETPOINT, THE ECONOMIZER WILL BE ENABLED. WHEN THE SHARED OUTSIDE AIR TEMPERATURE RISES ABOVE THE SWITCHOVER SETPOINT PLUS A DIFFERENTIAL, THE ECONOMIZER WILL BE DISABLED.

EXHUAUST FAN-3: WHEN THE BUILDING IS OCCUPIED BY SCHEDULE THE EXHUAUST FAN WILL BE STARTED.


SAFETY:
ALL OF THE SAFETY DEVICES ARE MANUAL RESET; THE DEVICE THAT HAS TRIPPED MUST BE MANUALLY RESET BEFORE RESTARTING THE AIR HANDLING UNIT.
IF A TEMPERATURE LOW LIMIT SWITCH SENSES A TEMPERATURE BELOW SETPOINT THE SUPPLY FAN WILL BE SHUTDOWN.
IF A FIRE ALARM SHUTDOWN CONTACT IS PROVIDED, THE SUPPLY FAN WILL BE SHUTDOWN WHEN TRIGGERED.

SHUTDOWN:
WHEN THE UNIT IS SHUTDOWN BY EITHER A STOP COMMAND OR SYSTEM SAFETY THE UNIT WILL BE SET AS FOLLOWS:
SUPPLY FAN WILL BE OFF
SUPPLY FAN VFD WILL BE COMMANDED TO 0%
OUTSIDE AIR DAMPER WILL CLOSE
RETURN AIR DAMPER WILL OPEN
COOLING VALVE WILL CLOSE

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND. COPYRIGHT JOHNSON CONTROLS, INC. 2007	Drawing Title											
	AHU 1 Flow Layout											
Project Title		REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN		DATE		BY
Charlottesville Airport Controls Upgrade		Sales Engineer		Project Manager		Application Engineer		DRAWN		APPROVED		
		BY		DATE		BY		DATE				
		Branch Information		CONTRACT NUMBER		DRAWING NUMBER						
		Johnson Controls		2315 Commerce Center Dr Suite D Rockville VA 23146		1-2744395808		AH1-1				

Electrician/Fitter		Point Information			Controller Information							Panel Information					Intermediate Device		
Tag	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device
					FEC 26xx	MS/TP	1	4						0					
	UI IN-1	AHU-1	DA-T	Discharge Air Temperature	FEC 26xx	MS/TP	1	4	UI IN-1					0		-4-UI IN-1			
	UI IN-2	AHU-1	DA1-P	Discharge Air Static Pressure	FEC 26xx	MS/TP	1	4	UI IN-2					0		-4-UI IN-2			
	UI IN-3	AHU-1	MA-T	Mixed Air Temperature	FEC 26xx	MS/TP	1	4	UI IN-3					0		-4-UI IN-3			
	UI IN-4	AHU-1	RA-T	Return Air Temperature	FEC 26xx	MS/TP	1	4	UI IN-4					0		-4-UI IN-4			
	UI IN-5	AHU-1	RA-H	Return Air Humidity	FEC 26xx	MS/TP	1	4	UI IN-5					0		-4-UI IN-5			
	UI IN-6	AHU-1			FEC 26xx	MS/TP	1	4	UI IN-6					0		-4-UI IN-6			
	BI IN-7	AHU-1	LT-A	Low Temperature Alarm	FEC 26xx	MS/TP	1	4	BI IN-7					0		-4-BI IN-7			
	BI IN-8	AHU-1	SF-S	Supply Fan Status	FEC 26xx	MS/TP	1	4	BI IN-8					0		-4-BI IN-8			
	BO OUT-1	AHU-1	EF3-C	Exhaust Fan 3 Command	FEC 26xx	MS/TP	1	4	BO OUT-1					0		-4-BO OUT-1			
	BO OUT-2	AHU-1	SF-C	Supply Fan Command	FEC 26xx	MS/TP	1	4	BO OUT-2					0		-4-BO OUT-2			
	BO OUT-3	AHU-1			FEC 26xx	MS/TP	1	4	BO OUT-3					0		-4-BO OUT-3			
	CO OUT-4	AHU-1	SF-O	Supply Fan Output	FEC 26xx	MS/TP	1	4	CO OUT-4					0		-4-CO OUT-4			
	CO OUT-5	AHU-1			FEC 26xx	MS/TP	1	4	CO OUT-5					0		-4-CO OUT-5			
	CO OUT-6	AHU-1			FEC 26xx	MS/TP	1	4	CO OUT-6					0		-4-CO OUT-6			
	CO OUT-7	AHU-1			FEC 26xx	MS/TP	1	4	CO OUT-7					0		-4-CO OUT-7			
	AO OUT-8	AHU-1	CLG-O	Cooling Output	FEC 26xx	MS/TP	1	4	AO OUT-8					0		-4-AO OUT-8			
	AO OUT-9	AHU-1	MAD-O	Mixed Air Damper Output	FEC 26xx	MS/TP	1	4	AO OUT-9					0		-4-AO OUT-9			

AHU-2



BILL OF MATERIALS

Designation	Qty	Part Number	Description
RA-T,DA-T	2	TE-6311M-1	1000 OHM NICKEL SENSOR
MA-T	1	TE-6316M-1	NICKEL DUCT AVERAGE SENSOR
AHU-2	1	MS-FEC2621-0	17 PT FIELD EQUIPMENT CONTROLLER

SUPPLY FAN START/STOP: THE SUPPLY FAN WILL BE STARTED ACCORDING TO THE SCHEDULE. IF THE SUPPLY FAN STATUS DOES NOT MATCH THE COMMANDED VALUE, AN ALARM WILL BE GENERATED. WHEN THE SUPPLY FAN STATUS INDICATES THE FAN STARTED, THE CONTROL SEQUENCE WILL BE ENABLED.

STATIC PRESSURE CONTROL: THE SUPPLY FAN WILL MODULATE TO MAINTAIN THE DISCHARGE STATIC PRESSURE AT SETPOINT 1.0 INWC (ADJUSTABLE).

DISCHARGE AIR CONTROL: THE MIXED AIR DAMPERS, AND THE COOLING VALVE WILL MODULATE IN SEQUENCE TO MAINTAIN THE DISCHARGE AIR TEMPERATURE AT SETPOINT 55 DEGF (ADJUSTABLE).

MIXED AIR LOW LIMIT OVERRIDE: THE MIXED AIR TEMPERATURE WILL OVERRIDE THE MINIMUM POSITION AND CLOSE THE OUTSIDE AIR DAMPER IF A TEMPERATURE IS SENSED BELOW THE SETPOINT 50 DEGF (ADJUSTABLE).

ECONOMIZER DRY BULB SWITCHOVER: WHEN THE SHARED OUTSIDE AIR TEMPERATURE IS BELOW THE SWITCHOVER SETPOINT, THE ECONOMIZER WILL BE ENABLED. WHEN THE SHARED OUTSIDE AIR TEMPERATURE RISES ABOVE THE SWITCHOVER SETPOINT PLUS A DIFFERENTIAL, THE ECONOMIZER WILL BE DISABLED.

EXHUAUST FANS-1&2: WHEN THE BUILDING IS OCCUPIED BY SCHEDULE THE EXHUAST FANS WILL BE STARTED.

SAFETY:
ALL OF THE SAFETY DEVICES ARE MANUAL RESET; THE DEVICE THAT HAS TRIPPED MUST BE MANUALLY RESET BEFORE RESTARTING THE AIR HANDLING UNIT.
IF A TEMPERATURE LOW LIMIT SWITCH SENSES A TEMPERATURE BELOW SETPOINT THE SUPPLY FAN WILL BE SHUTDOWN.
IF A FIRE ALARM SHUTDOWN CONTACT IS PROVIDED, THE SUPPLY FAN WILL BE SHUTDOWN WHEN TRIGGERED.

SHUTDOWN:
WHEN THE UNIT IS SHUTDOWN BY EITHER A STOP COMMAND OR SYSTEM SAFETY THE UNIT WILL BE SET AS FOLLOWS:
SUPPLY FAN WILL BE OFF
SUPPLY FAN VFD WILL BE COMMANDED TO 0%
OUTSIDE AIR DAMPER WILL CLOSE
RETURN AIR DAMPER WILL OPEN
COOLING VALVE WILL CLOSE

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND.

COPYRIGHT JOHNSON CONTROLS, INC. 2007

Drawing Title

AHU-2 Flow Layout

Project Title

Charlottesville Airport Controls Upgrade



2315 Commerce Center Dr Suite D Rockville VA 23146

CONTRACT NUMBER

1-2744395808

DRAWING NUMBER


AH2-1

Electrician/Fitter		Point Information			Controller Information						Panel Information					Intermediate Device			
	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device
Tag																			
					FEC 26xx														
					FEC 26xx	MS/TP	1	5						0					
	UI IN-1	AHU-2	DA-T	Discharge Air Temperature	FEC 26xx	MS/TP	1	5	UI IN-1					0		-5-UI IN-1			
	UI IN-2	AHU-2	DA1-P	Discharge Air Static Pressure	FEC 26xx	MS/TP	1	5	UI IN-2					0		-5-UI IN-2			
	UI IN-3	AHU-2	MA-T	Mixed Air Temperature	FEC 26xx	MS/TP	1	5	UI IN-3					0		-5-UI IN-3			
	UI IN-4	AHU-2	RA-T	Return Air Temperature	FEC 26xx	MS/TP	1	5	UI IN-4					0		-5-UI IN-4			
	UI IN-5	AHU-2	RA-H	Return Air Humidity	FEC 26xx	MS/TP	1	5	UI IN-5					0		-5-UI IN-5			
	UI IN-6	AHU-2			FEC 26xx	MS/TP	1	5	UI IN-6					0		-5-UI IN-6			
	BI IN-7	AHU-2	LT-A	Low Temperature Alarm	FEC 26xx	MS/TP	1	5	BI IN-7					0		-5-BI IN-7			
	BI IN-8	AHU-2	SF-S	Supply Fan Status	FEC 26xx	MS/TP	1	5	BI IN-8					0		-5-BI IN-8			
	BO OUT-1	AHU-2	EF2-C	Exhaust Fan 2 Command	FEC 26xx	MS/TP	1	5	BO OUT-1					0		-5-BO OUT-1			
	BO OUT-2	AHU-2	EF1-C	Exhaust Fan 1 Command	FEC 26xx	MS/TP	1	5	BO OUT-2					0		-5-BO OUT-2			
	BO OUT-3	AHU-2	SF-C	Supply Fan Command	FEC 26xx	MS/TP	1	5	BO OUT-3					0		-5-BO OUT-3			
	CO OUT-4	AHU-2	SF-O	Supply Fan Output	FEC 26xx	MS/TP	1	5	CO OUT-4					0		-5-CO OUT-4			
	CO OUT-5	AHU-2			FEC 26xx	MS/TP	1	5	CO OUT-5					0		-5-CO OUT-5			
	CO OUT-6	AHU-2			FEC 26xx	MS/TP	1	5	CO OUT-6					0		-5-CO OUT-6			
	CO OUT-7	AHU-2			FEC 26xx	MS/TP	1	5	CO OUT-7					0		-5-CO OUT-7			
	AO OUT-8	AHU-2	CLG-O	Cooling Output	FEC 26xx	MS/TP	1	5	AO OUT-8					0		-5-AO OUT-8			
	AO OUT-9	AHU-2	MAD-O	Mixed Air Damper Output	FEC 26xx	MS/TP	1	5	AO OUT-9					0		-5-AO OUT-9			

AHU-3

BILL OF MATERIALS

Designation	Qty	Part Number	Description
RA-T,DA-T	2	TE-6311M-1	1000 OHM NICKEL SENSOR
MA-T	1	TE-6316M-1	NICKEL DUCT AVERAGE SENSOR
AHU-3	1	MS-FEC2621-0	17 PT FIELD EQUIPMENT CONTROLLER



SUPPLY FAN START/STOP: THE SUPPLY FAN WILL BE STARTED ACCORDING TO THE SCHEDULE. IF THE SUPPLY FAN STATUS DOES NOT MATCH THE COMMANDED VALUE, AN ALARM WILL BE GENERATED. WHEN THE SUPPLY FAN STATUS INDICATES THE FAN STARTED, THE CONTROL SEQUENCE WILL BE ENABLED.

STATIC PRESSURE CONTROL: THE SUPPLY FAN WILL MODULATE TO MAINTAIN THE DISCHARGE STATIC PRESSURE AT SETPOINT 1.0 INWC (ADJUSTABLE).

DISCHARGE AIR CONTROL: THE MIXED AIR DAMPERS, AND THE COOLING VALVE WILL MODULATE IN SEQUENCE TO MAINTAIN THE DISCHARGE AIR TEMPERATURE AT SETPOINT 55 DEGF (ADJUSTABLE).

MIXED AIR LOW LIMIT OVERRIDE: THE MIXED AIR TEMPERATURE WILL OVERRIDE THE MINIMUM POSITION AND CLOSE THE OUTSIDE AIR DAMPER IF A TEMPERATURE IS SENSED BELOW THE SETPOINT 50 DEGF (ADJUSTABLE).


ECONOMIZER DRY BULB SWITCHOVER: WHEN THE SHARED OUTSIDE AIR TEMPERATURE IS BELOW THE SWITCHOVER SETPOINT, THE ECONOMIZER WILL BE ENABLED. WHEN THE SHARED OUTSIDE AIR TEMPERATURE RISES ABOVE THE SWITCHOVER SETPOINT PLUS A DIFFERENTIAL, THE ECONOMIZER WILL BE DISABLED.

SAFETY:
ALL OF THE SAFETY DEVICES ARE MANUAL RESET; THE DEVICE THAT HAS TRIPPED MUST BE MANUALLY RESET BEFORE RESTARTING THE AIR HANDLING UNIT.
IF A TEMPERATURE LOW LIMIT SWITCH SENSES A TEMPERATURE BELOW SETPOINT THE SUPPLY FAN WILL BE SHUTDOWN.
IF A FIRE ALARM SHUTDOWN CONTACT IS PROVIDED, THE SUPPLY FAN WILL BE SHUTDOWN WHEN TRIGGERED.

SHUTDOWN:
WHEN THE UNIT IS SHUTDOWN BY EITHER A STOP COMMAND OR SYSTEM SAFETY THE UNIT WILL BE SET AS FOLLOWS:
SUPPLY FAN WILL BE OFF
SUPPLY FAN VFD WILL BE COMMANDED TO 0%
OUTSIDE AIR DAMPER WILL CLOSE
RETURN AIR DAMPER WILL OPEN
COOLING VALVE WILL CLOSE

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND. COPYRIGHT JOHNSON CONTROLS, INC. 2007	Drawing Title AHU-3 Flow Layout								
	Project Title Charlottesville Airport Controls Upgrade		REFERENCE DRAWINGS		NO.	REVISION-LOCATION		ECN	DATE
			Sales Engineer	Project Manager	Application Engineer	DRAWN		APPROVED	
						BY	DATE	BY	DATE
						Branch Information		CONTRACT NUMBER	
		Johnson Controls		2315 Commerce Center Dr Suite D Rockville VA 23146		1-2744395808		DRAWING NUMBER	
								AH3-1	

AHU-5



BILL OF MATERIALS

Designation	Qty	Part Number	Description
RA-T,DA-T	2	TE-6311M-1	1000 OHM NICKEL SENSOR
MA-T	1	TE-6316M-1	NICKEL DUCT AVERAGE SENSOR
AHU-5	1	MS-FEC2621-0	17 PT FIELD EQUIPMENT CONTROLLER

SUPPLY FAN START/STOP: THE SUPPLY FAN WILL BE STARTED ACCORDING TO THE SCHEDULE. IF THE SUPPLY FAN STATUS DOES NOT MATCH THE COMMANDED VALUE, AN ALARM WILL BE GENERATED. WHEN THE SUPPLY FAN STATUS INDICATES THE FAN STARTED, THE CONTROL SEQUENCE WILL BE ENABLED.

DISCHARGE AIR CONTROL: THE DISCHARGE AIR TEMPERATURE SETPOINT WILL RESET AS NECESSARY TO MAINTAIN THE RETURN TEMPERATURE SETPOINT AS SENSED BY THE RETURN TEMPERATURE SENSOR. THE MIXED AIR DAMPERS, HEATING VALVE, AND THE COOLING VALVE WILL MODULATE IN SEQUENCE TO MAINTAIN THE DISCHARGE AIR TEMPERATURE AT SETPOINT.

MIXED AIR LOW LIMIT OVERRIDE: THE MIXED AIR TEMPERATURE WILL OVERRIDE THE MINIMUM POSITION AND CLOSE THE OUTSIDE AIR DAMPER IF A TEMPERATURE IS SENSED BELOW THE SETPOINT.

ECONOMIZER DRY BULB SWITCHOVER: WHEN THE SHARED OUTSIDE AIR TEMPERATURE IS BELOW THE SWITCHOVER SETPOINT, THE ECONOMIZER WILL BE ENABLED. WHEN THE SHARED OUTSIDE AIR TEMPERATURE RISES ABOVE THE SWITCHOVER SETPOINT PLUS A DIFFERENTIAL, THE ECONOMIZER WILL BE DISABLED.

SAFETY:
ALL OF THE SAFETY DEVICES ARE MANUAL RESET; THE DEVICE THAT HAS TRIPPED MUST BE MANUALLY RESET BEFORE RESTARTING THE AIR HANDLING UNIT.
IF A TEMPERATURE LOW LIMIT SWITCH SENSES A TEMPERATURE BELOW SETPOINT THE SUPPLY FAN WILL BE SHUTDOWN.
IF A FIRE ALARM SHUTDOWN CONTACT IS PROVIDED, THE SUPPLY FAN WILL BE SHUTDOWN WHEN TRIGGERED.

SHUTDOWN:
WHEN THE UNIT IS SHUTDOWN BY EITHER A STOP COMMAND OR SYSTEM SAFETY THE UNIT WILL BE SET AS FOLLOWS:
SUPPLY FAN WILL BE OFF
OUTSIDE AIR DAMPER WILL CLOSE
RETURN AIR DAMPER WILL OPEN
COOLING VALVE WILL CLOSE
HEATING VALVE WILL CLOSE

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND.

COPYRIGHT JOHNSON CONTROLS, INC. 2007



Drawing Title AHU 5 Flow Layout											
	REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN		DATE		BY
	Sales Engineer		Project Manager		Application Engineer		DRAWN		APPROVED		
							BY		DATE		
Project Title Charlottesville Airport Controls Upgrade	Johnson Controls		Branch Information 2315 Commerce Center Dr Suite D Rockville VA 23146		CONTRACT NUMBER						
					DRAWING NUMBER		AH5-1				

Electrician/Fitter		Point Information			Controller Information							Panel Information					Intermediate Device		
Tag	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device
					FEC 26xx														
					FEC 26xx	MS/TP	1	7						0					
	UI IN-1	AHU-5	DA-T	Discharge Air Temperature	FEC 26xx	MS/TP	1	7	UI IN-1					0		-7-UI IN-1			
	UI IN-2	AHU-5	MA-T	Mixed Air Temperature	FEC 26xx	MS/TP	1	7	UI IN-2					0		-7-UI IN-2			
	UI IN-3	AHU-5	RA-T	Return Air Temperature	FEC 26xx	MS/TP	1	7	UI IN-3					0		-7-UI IN-3			
	UI IN-4	AHU-5	RA-H	Return Air Humidity	FEC 26xx	MS/TP	1	7	UI IN-4					0		-7-UI IN-4			
	UI IN-5	AHU-5			FEC 26xx	MS/TP	1	7	UI IN-5					0		-7-UI IN-5			
	UI IN-6	AHU-5			FEC 26xx	MS/TP	1	7	UI IN-6					0		-7-UI IN-6			
	BI IN-7	AHU-5	LT-A	Low Temperature Alarm	FEC 26xx	MS/TP	1	7	BI IN-7					0		-7-BI IN-7			
	BI IN-8	AHU-5	SF-S	Supply Fan Status	FEC 26xx	MS/TP	1	7	BI IN-8					0		-7-BI IN-8			
	BO OUT-1	AHU-5	SF-C	Supply Fan Command	FEC 26xx	MS/TP	1	7	BO OUT-1					0		-7-BO OUT-1			
	BO OUT-2	AHU-5			FEC 26xx	MS/TP	1	7	BO OUT-2					0		-7-BO OUT-2			
	BO OUT-3	AHU-5			FEC 26xx	MS/TP	1	7	BO OUT-3					0		-7-BO OUT-3			
	CO OUT-4	AHU-5	RH-O	Reheat Output	FEC 26xx	MS/TP	1	7	CO OUT-4					0		-7-CO OUT-4			
	CO OUT-5	AHU-5			FEC 26xx	MS/TP	1	7	CO OUT-5					0		-7-CO OUT-5			
	CO OUT-6	AHU-5			FEC 26xx	MS/TP	1	7	CO OUT-6					0		-7-CO OUT-6			
	CO OUT-7	AHU-5			FEC 26xx	MS/TP	1	7	CO OUT-7					0		-7-CO OUT-7			
	AO OUT-8	AHU-5	CLG-O	Cooling Output	FEC 26xx	MS/TP	1	7	AO OUT-8					0		-7-AO OUT-8			
	AO OUT-9	AHU-5	MAD-O	Mixed Air Damper Output	FEC 26xx	MS/TP	1	7	AO OUT-9					0		-7-AO OUT-9			

VAV System

BILL OF MATERIALS

Designation	Qty	Part Number	Description
ZN-T	62	NS-BTN7001-0	NETWORK SENSOR
DA-T	62	TE-631GV-2	4 INCH NICKEL DUCT SENSOR
VAV	62	MS-VMA1620-0	BACNET MS/TP VAV CONTROLLER



DISCHARGE AIR TEMP SENSOR: A DISCHARGE AIR TEMP SENSOR IS PROVIDED ON EACH BOX FOR MONITORING PURPOSES.

OCCUPIED MODE: WHEN THE ZONE TEMPERATURE IS BETWEEN THE OCCUPIED HEATING AND COOLING SETPOINTS (INSIDE OF THE BIAS), THE PRIMARY AIR DAMPER WILL BE AT THE MINIMUM CFM AND THE REHEAT VALVE WILL BE FULLY CLOSED. ON A RISE IN ZONE TEMPERATURE ABOVE THE COOLING SETPOINT, THE PRIMARY AIR DAMPER WILL INCREASE THE CFM AND THE REHEAT VALVE REMAINS FULLY CLOSED. ON A DROP IN ZONE TEMPERATURE BELOW THE HEATING SETPOINT, THE FAN WILL CYCLE ON, THE REHEAT VALVE MODULATES OPEN AND THE DAMPER IS CONTROLLED TO PROVIDE A MINIMUM CFM.

UNOCCUPIED (NIGHT SETBACK) MODE: WHEN THE AIR HANDLING UNIT SHUTS DOWN, ALL OF THE FAN-POWERED BOX CONTROLLERS ARE INDEXED TO UNOCCUPIED MODE. WHEN THE ZONE TEMPERATURE IS BETWEEN THE UNOCCUPIED HEATING AND COOLING SETPOINTS (INSIDE OF THE BIAS), THE PRIMARY AIR DAMPER WILL BE AT THE MINIMUM CFM AND THE REHEAT VALVE WILL BE FULLY CLOSED. ON A RISE IN ZONE TEMPERATURE ABOVE THE UNOCCUPIED COOLING SETPOINT, THE PRIMARY AIR DAMPER WILL INCREASE THE CFM (IF AVAILABLE) AND THE REHEAT VALVE REMAINS FULLY CLOSED. ON A DROP IN ZONE TEMPERATURE BELOW THE UNOCCUPIED HEATING SETPOINT, THE FAN WILL CYCLE ON, THE REHEAT VALVE MODULATES OPEN AND THE DAMPER REMAIN FULLY CLOSED.

FOR BOX PARAMETERS AND SETTINGS SEE THE ROOM SCHEDULE

IN CONSIDERATION OF THE RECEIPT OF THIS DOCUMENT, THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, USE OR TRANSMIT THIS DOCUMENT AND/OR THE INFORMATION THEREIN CONTAINED, IN WHOLE OR IN PART, OR TO SUFFER SUCH ACTION BY OTHERS, FOR ANY PURPOSE, EXCEPT WITH THE ADVANCE WRITTEN PERMISSION OF JOHNSON CONTROLS, INC. AND FURTHER AGREES TO SURRENDER SAME TO JOHNSON CONTROLS, INC. UPON DEMAND. COPYRIGHT JOHNSON CONTROLS, INC. 2007	Drawing Title VAV Flow Layout												
Project Title Charlottesville Airport Controls Upgrade													

Electrician/Fitter		Point Information			Controller Information						Panel Information						Intermediate Device		
Tag	Point Type	System Name	Object Name	Expanded ID	Controller Details	Trunk Type	Trunk Nbr	Trunk Addr.	Cable Destination Bay/Terminal	Module Type	Termination Out	Panel	Panel Location	Slot Number	Reference Drawing	Cable Number	Wiring /Tubing	Termination In	Device
					VMA 1620														
					VMA 1620	MS/TP	1	10						0					
	UI IN-1	VAV-00	DA-T	Discharge Air Temperature	VMA 1620	MS/TP	1	10	UI IN-1					0		-10-UI IN-1			
	BO OUT-1	VAV-00	HTG-O	Heating Output	VMA 1620	MS/TP	1	10	BO OUT-1					0		-10-BO OUT-1			
	BO OUT-2	VAV-00	HTG-O	Heating Output	VMA 1620	MS/TP	1	10	BO OUT-2					0		-10-BO OUT-2			
	BO OUT-3	VAV-00	SF-C	Supply Fan Command	VMA 1620	MS/TP	1	10	BO OUT-3					0		-10-BO OUT-3			
	CO OUT-4	VAV-00			VMA 1620	MS/TP	1	10	CO OUT-4					0		-10-CO OUT-4			
	CO OUT-5	VAV-00			VMA 1620	MS/TP	1	10	CO OUT-5					0		-10-CO OUT-5			
		VAV-00			NET STAT														
		VAV-00			NET STAT	SA Bus	1	199						0					
	STAT	VAV-00	ZN-T	Zone Temperature	NET STAT	SA Bus	1	199	STAT					0		10--199-STAT			

Box Location								Controller Information					Box Information											
Room								JCI Ctrl Dwg No.	Controller Required					Box Heat	Supplemental Heat	Box Config Required						Required (N2)		Generate Flag
Bldg./Flr.	No.	Name	System Name	Mech. Dwg.	System Serving this Box	Box Mfgr.	Mfgr Box Type		Controller Part No.	NC/ NAE Addr	Trunk ID	Device Addr	CSModel or Template			Config File Name	Inlet Size (Inches)	Inlet Area (Sq. Ft.)	K Factor	Clg Min Flow	Clg Max Flow	VMA Box Config	Comments	
			VAV1-01							1	1	10												
			VAV1-02							1	1	11												
			VAV1-03							1	1	12												
			VAV1-04							1	1	13												
			VAV1-05							1	1	14												
			VAV1-06							1	1	15												
			VAV1-07							1	1	16												
			VAV1-08							1	1	17												
			VAV1-09							1	1	18												
			VAV1-10							1	1	19												
			VAV1-11							1	1	20												
			VAV1-12							1	1	21												
			VAV1-13							1	1	22												
			VAV1-14							1	1	23												
			VAV1-15							1	1	24												
			VAV1-16							1	1	25												
			VAV1-17							1	1	26												
			VAV1-18							1	1	27												
			VAV1-19							1	1	28												
			VAV1-20							1	1	29												
			VAV1-21							1	1	30												
			VAV1-22							1	1	31												
			VAV1-23							1	1	32												
			VAV1-25							1	1	33												
			VAV1-26							1	1	34												
			VAV1-27							1	1	35												
			VAV1-28							1	1	36												
			VAV1-29							1	1	37												
			VAV1-30							1	1	38												
			VAV1-31							1	1	39												
			VAV1-32							1	1	40												
			VAV1-33							1	1	41												
			VAV1-34							1	1	42												
			VAV1-35							1	2	4												
			VAV1-36							1	2	5												
			VAV1-37							1	2	6												
			VAV1-38							1	2	7												
			VAV1-39							1	2	8												
			VAV1-40							1	2	9												
			VAV1-41							1	2	10												
			VAV1-42							1	2	11												
			VAV1-43							1	2	12												
			VAV1-44							1	2	13												
			VAV1-45							1	2	14												
			VAV1-46							1	2	15												
			VAV2-01							1	2	16												
			VAV2-02							1	2	17												
			VAV2-04							1	2	18												
			VAV2-05							1	2	19												
			VAV2-06							1	2	20												
			VAV2-07							1	2	21												

Box Location								Controller Information						Box Information											Generate Flag
Bldg./Flr.	Room		System Name	Mech. Dwg.	System Serving this Box	Box Mfrgr.	Mfrgr Box Type	JCI Ctrl Dwg No.	Controller				CSModel or Template	Box Heat	Supplemental Heat	Box Config						Required (N2)		Comments	
	No.	Name							Controller Part No.	NC/ NAE Addr	Trunk ID	Device Addr				Config File Name	Inlet Size (Inches)	Inlet Area (Sq. Ft.)	K Factor	Clg Min Flow	Clg Max Flow	VMA Box Config			
																							Required		
			VAV2-08							1	2	22													
			VAV2-09							1	2	23													
			VAV2-10							1	2	24													
			VAV2-11							1	2	25													
			VAV2-12							1	2	26													
			VAV2-13							1	2	27													
			VAV2-14							1	2	28													
			VAV2-15							1	2	29													
			VAV2-16							1	2	30													
			VAV2-17							1	2	31													
			VAV2-18							1	2	32													